




Nationwide
is on your side

Safety Matters

Electric Vehicle Charging Stations

As electric vehicles become more available and popular, there are certain hazards that must be controlled when designing and maintaining the charging site. The following are some basic considerations in the design and operation of these charging sites

- As vehicles are charging, hydrogen gas is often produced, and we must provide adequate airflow/ventilation in the charging area, such as charging outdoors and eliminating any ignition sources near the charging stations.
- Charging can be a dangerous fire hazard, so adequate distance from any outdoor structure is advisable.
- Charging stations should be in a designated “safe” area away from any ignition sources and accidental vehicle strikes/traffic. There must be adequate egress from the charging area, adequate distance from structures, and emergency shut-offs must be clearly identified.



The information used to create this brochure was obtained from sources believed to be reliable. Nationwide, its affiliates and employees do not guarantee improved results based upon the information contained herein and assume no liability in connection with the information or the provided safety suggestions. The recommendations provided are general in nature; unique circumstances may not warrant or require implementation of some or all of the safety suggestions. There may be additional available safety procedures that are not referenced in this brochure. Nationwide, Nationwide is on your side, and the Nationwide N and Eagle are service marks of Nationwide Mutual Insurance Company. © 2021 Nationwide